



Product Technical Data Sheet:

**TDSCIPC**

**PFC Corofil Intumescent  
Pipe Collars CIPC**

ETA Number: 20/1151

20/1147



**SERVICE  
PENETRATIONS**



## Technical Description of Product



PFC Corofil Intumescent Pipe Collars are designed and tested to provide a fire-resistant seal in flexible walls, rigid walls, rigid floors, and PFC Corofil Coated panels where they have been penetrated by service penetrations containing plastic pipes and metallic pipes with insulation.

PFC Corofil Intumescent Pipe Collars have been tested to EN1366-3 and offer fire resistance periods of up to EI240 for differing services and wall/floor constructions. They are manufactured with an intumescent coating incorporated in a thin steel casing which are available 30mm deep and 40mm deep and up to 250mm diameter. In the event of a fire the intumescent will expand when heated, providing a closure of combustible pipes to prevent the passage of fire between compartments.

PFC Corofil Intumescent Pipe Collars are supplied in assembled form without fixings. The collar is wrapped around the pipe at the soffit or on both sides of the wall. The annular gap around the pipes should be sealed using PFC Corofil Acoustic Intumescent Sealant.

## Intended Use

---

The intended use of PFC Corofil Intumescent Pipe Collars is to reinstate the fire resistance performance of wall and floor constructions where they are penetrated by various combustible pipe services.

The specific elements of construction that PFC Corofil Intumescent Pipe Collars may be used with is listed under **Substrates** on page 5 of this data sheet.

This data sheet shows the only applications the product has been tested in. Please ensure the product has been tested in and is suitable for your application (see PFC Corofil terms and conditions 13.1.1).

## Key Points

---

- Conditioned to Type X: Intended for conditions exposed to weathering -20°C to +70°C. Tested in accordance with EOTA TR024. Products for penetration seals intended for outdoor use exposed to weathering – rain, UV, high temperatures, frost and frost thaw in winter.
- PFC Corofil Intumescent Pipe Collars have an assumed working life of 10 years. The indications of a working life can not be assumed as a guarantee given by PFC Corofil, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

Technical Data



Specification

Description	Result	Test Standard
Pipe Diameter	32mm, 40mm, 50mm, 55mm, 63mm, 75mm, 82mm, 90mm, 100mm, 110mm, 125mm, 140mm, 160mm, 200mm, 250mm,	
Plastic Pipe Material	PVC-U, PVC-C, ABS, SAN+ PVC, PE-HD, PE, PP	
Fire Resistance Rigid Floors	Up to EI240 (fixed to the underside)	EN1366-3
Fire Resistance Flexible & Rigid Walls	Up to EI120 (fixed one on each side)	EN1366-3
Expansion Ratio	20:1	EOTA TR 024
Expansion Pressure N/mm <sup>2</sup>	1.30	EOTA TR 024
Working Temperature	-20°C to +70°C	
Colour/Appearance	Red Steel casing with 3 fixing tabs	

Fixing Detail:		
Flexible Walls	3No. 6mm x 65mm Steel toggle anchor	
Rigid walls & Rigid Floors	3No. 8mm ø x 60mm FSA with M6 Hex head bolts 3No. 4mm x 70mm Wood screws with penny washers 3No. 40mm hammer fixings	
Coated panel	3No. 80mm pigtails	

## Installation Instructions



- PFC Corofil Intumescent Pipe Collars provide a penetration seal with specific combustible pipes, single pipes only. See Performance Data tables from page 6 for details.
  - Ensure that the aperture and penetration to be sealed is free from dust, grease and obstructions which will affect a flush fit of the PFC Corofil Intumescent Pipe Collar to the surface.
  - Ensure that the substrates and services have been tested for use with the PFC Corofil Intumescent Pipe Collar and that the site conditions are within the application specification.
  - Apertures for pipe penetrations shall be separated by a minimum 200mm.
  - Services in walls shall be supported at maximum 400mm from the face of the separating element on both sides.
  - Services in floors shall be supported at maximum 400mm from the top surface of the floor.
  - An annular gap, maximum 10mm, is required around the services and should be sealed using PFC Corofil Acoustic Intumescent Sealant (see Technical Datasheet TDSCAIS for details) before installing the PFC Corofil Intumescent Pipe Collar.
  - Place the collar around the pipe and hold in place using the slide clip to slip through the loop and bend back on itself to secure the collar tightly.
  - Slide the collar into place against the separating element ensuring a flush fit.
  - Fix the collar through each of the 3 lugs to the separating element using the correct fixings for the substrate the collar is being installed against (see table on page 3 for correct fixings).
-

## Installation Instructions



### Substrates

---

- Flexible walls: Minimum 100mm thick, comprising of metal or timber studs lined on both sides with 2 layers of 12.5mm 'type F' gypsum plasterboards according to EN520. In timber stud walls, no part of the penetration shall be closer than 100mm to the timber stud. A minimum 100mm of either class A1 or A2 insulation according to EN13501-1 shall be provided within the cavity between the penetration and the stud.
  - Rigid walls: Minimum 100mm thick and comprise of concrete, aerated concrete or masonry, with a minimum density of 650kg/m<sup>3</sup>.
  - Rigid floors: Minimum 150mm thick and comprise of concrete, aerated concrete or masonry, with a minimum density of 650kg/m<sup>3</sup>.
  - PFC Corofil Coated Panel system.
- 

### Terminology

---

**Fire resistance classes:**

E = Integrity. The length of time it takes for the fire to pass to the non fire side.

I = Insulation. The length of time it takes for the heat of the fire to pass to the non fire side.

**Furnace classification:**

U/U = Uncapped in the furnace/Uncapped outside the furnace

U/C = Uncapped in the furnace/Capped outside the furnace

C/U = Capped inside the furnace/Uncapped outside the furnace

**Performance Data**



Walls minimum thickness 100mm  
 Flexible or Rigid Wall  
 PVC-u Pipes according to EN1452

PFC Corofil Intumescent Pipe Collars installed on both sides of a flexible or rigid wall, minimum thickness 100mm - PVC-u pipes.			
Penetration Specification	Collar Reference	Annulus Space	Classification
PVC pipe 32mm ø 1.8mm wall thickness	32mm x 30mm x 4mm CIPC	10mm	E120 U/C
PVC pipe 40mm ø 1.8mm wall thickness	40mm x 30mm x 4mm CIPC		
PVC pipe 55mm ø 2.3mm - 3.0mm wall thickness	55mm x 30mm x 6mm CIPC		
PVC pipe 63mm ø 2.3mm - 3.0mm wall thickness	63mm x 30mm x 6mm CIPC		
PVC pipe 75mm ø 3.1mm - 4.8mm wall thickness	75mm x 30mm x 8mm CIPC		
PVC pipe 82mm ø 3.1mm - 4.8mm wall thickness	82mm x 30mm x 8mm CIPC		
PVC pipe 90mm ø 4.2mm - 7.4mm wall thickness	90mm x 30mm x 10mm CIPC		
PVC pipe 110mm ø 4.2mm - 7.4mm wall thickness	110mm x 30mm x 10mm CIPC		
PVC pipe 125mm ø 6.0mm wall thickness	125mm x 40mm x 12mm CIPC		
PVC pipe 160mm ø 6.2mm - 9.5mm wall thickness	160mm x 40mm x 18mm CIPC		

PE Pipes according to EN ISO 15494

PFC Corofil Intumescent Pipe Collars installed on both sides of a flexible or rigid wall, minimum thickness 100mm - PE pipes.			
Penetration Specification	Collar Reference	Annulus Space	Classification
PE pipe 32mm ø 2.9mm wall thickness	32mm x 30mm x 4mm CIPC	10mm	E120 U/C
PE pipe 40mm ø 2.9mm wall thickness	40mm x 30mm x 4mm CIPC		
PE pipe 55mm ø 2.9mm - 4.4mm wall thickness	55mm x 30mm x 6mm CIPC		
PE pipe 63mm ø 2.9mm - 4.4mm wall thickness	63mm x 30mm x 6mm CIPC		
PE pipe 75mm ø 2.8mm - 6.7mm wall thickness	75mm x 30mm x 8mm CIPC		
PE pipe 82mm ø 2.8mm - 6.7mm wall thickness	82mm x 30mm x 8mm CIPC		
PE pipe 90mm ø 2.7mm - 10.0mm wall thickness	90mm x 30mm x 10mm CIPC		
PE pipe 110mm ø 2.7mm - 10.0mm wall thickness	110mm x 30mm x 10mm CIPC		
PE pipe 125mm ø 3.1mm wall thickness	125mm x 40mm x 12mm CIPC		
PE pipe 160mm ø 4.9mm - 9.5mm wall thickness	160mm x 40mm x 18mm CIPC		

**Performance Data**



Walls minimum thickness 100mm

Flexible or Rigid Wall

PP Pipes according to EN1451

PFC Corofil Intumescent Pipe Collars installed on both sides of a flexible or rigid wall, minimum thickness 100mm - PP pipes.			
Penetration Specification	Collar Reference	Annulus Space	Classification
PP pipe 32mm ø 2.9mm wall thickness	32mm x 30mm x 4mm CIPC	10mm	EI120 U/C
PP pipe 40mm ø 2.9mm wall thickness	40mm x 30mm x 4mm CIPC		
PP pipe 55mm ø 2.9mm - 4.4mm wall thickness	55mm x 30mm x 6mm CIPC		
PP pipe 63mm ø 2.9mm - 4.4mm wall thickness	63mm x 30mm x 6mm CIPC		
PP pipe 75mm ø 2.8mm - 6.7mm wall thickness	75mm x 30mm x 8mm CIPC		
PP pipe 82mm ø 2.8mm - 6.7mm wall thickness	82mm x 30mm x 8mm CIPC		
PP pipe 90mm ø 2.7mm - 10.0mm wall thickness	90mm x 30mm x 10mm CIPC		
PP pipe 110mm ø 2.7mm - 10.0mm wall thickness	110mm x 30mm x 10mm CIPC		
PP pipe 125mm ø 3.1mm wall thickness	125mm x 40mm x 12mm CIPC		
PP pipe 160mm ø 4.0mm - 14.6mm wall thickness	160mm x 40mm x 18mm CIPC		

Rigid Wall

PP Pipes according to EN 1451

PFC Corofil Intumescent Pipe Collars installed on both sides of a rigid wall, minimum thickness 100mm - PP pipes.			
Penetration Specification	Collar Reference	Annulus Space	Classification
PP pipe 110mm ø 2.7mm wall thickness	110mm x 30mm x 10mm CIPC	10mm	EI120 U/U
PP pipe 160mm ø 4.0mm wall thickness	160mm x 40mm x 18mm CIPC		EI120 U/U
PP pipe 250mm ø 6.2mm wall thickness	250mm x 40mm x 24mm CIPC		EI120 U/C



Performance Data



Walls minimum thickness 100mm  
 PFC Corofil Coated Panel installed as a double layer within the wall  
 PVC-u Pipes according to EN1452

PFC Corofil Intumescent Pipe Collars installed on each outer face of a double layer of PFC Corofil Coated Panel 50mm within a flexible or rigid wall, minimum thickness 100mm. Maximum aperture 730mm wide x 1200mm high - PVC-u pipes.			
Penetration Specification	Collar Reference	Penetration Formation	Classification
PVC pipe 32mm ø 1.8mm wall thickness	32mm x 30mm x 4mm CIPC	Cluster Formation of pipes with 0mm separation  There must be a minimum of 50mm from the edge of the seal	EI120 U/C
PVC pipe 40mm ø 1.8mm wall thickness	40mm x 30mm x 4mm CIPC		
PVC pipe 55mm ø 1.8mm - 2.3mm wall thickness	55mm x 30mm x 6mm CIPC		
PVC pipe 63mm ø 2.3mm - 3.0mm wall thickness	63mm x 30mm x 6mm CIPC		
PVC pipe 75mm ø 3.1mm - 4.8mm wall thickness	75mm x 30mm x 8mm CIPC		
PVC pipe 82mm ø 3.1mm - 4.8mm wall thickness	82mm x 30mm x 8mm CIPC		
PVC pipe 90mm ø 4.2mm - 7.4mm wall thickness	90mm x 30mm x 10mm CIPC		
PVC pipe 110mm ø 4.2mm - 7.4mm wall thickness	110mm x 30mm x 10mm CIPC		
PVC pipe 125mm ø 6mm wall thickness	125mm x 40mm x 12mm CIPC		
PVC pipe 160mm ø 6.2mm - 9.5mm wall thickness	160mm x 40mm x 18mm CIPC		

PE Pipes according to EN ISO 15494

PFC Corofil Intumescent Pipe Collars installed on each outer face of a double layer of PFC Corofil Coated Panel 50mm within a flexible or rigid wall, minimum thickness 100mm. Maximum aperture 730mm wide x 1200mm high - PE pipes.			
Penetration Specification	Collar Reference	Penetration Formation	Classification
PE pipe 32mm ø 2.9mm wall thickness	32mm x 30mm x 4mm CIPC	Cluster Formation of pipes with 0mm separation  There must be a minimum of 50mm from the edge of the seal	EI120 U/C
PE pipe 40mm ø 2.9mm wall thickness	40mm x 30mm x 4mm CIPC		
PE pipe 55mm ø 2.9mm - 4.4mm wall thickness	55mm x 30mm x 6mm CIPC		
PE pipe 63mm ø 2.9mm - 4.4mm wall thickness	63mm x 30mm x 6mm CIPC		
PE pipe 75mm ø 2.8mm - 6.7mm wall thickness	75mm x 30mm x 8mm CIPC		
PE pipe 82mm ø 2.8mm - 6.7mm wall thickness	82mm x 30mm x 8mm CIPC		
PE pipe 90mm ø 2.7mm - 10.0mm wall thickness	90mm x 30mm x 10mm CIPC		
PE pipe 110mm ø 2.7mm - 10.0mm wall thickness	110mm x 30mm x 10mm CIPC		
PE pipe 125mm ø 3.1mm wall thickness	125mm x 40mm x 12mm CIPC		
PE pipe 160mm ø 4.9mm - 9.5mm wall thickness	160mm x 40mm x 18mm CIPC		



**Performance Data**



Walls minimum thickness 100mm

PFC Corofil Coated Panel installed as a double layer within the wall

PP Pipes according to EN1451

PFC Corofil Intumescent Pipe Collars installed on each outer face of a double layer of PFC Corofil Coated Panel 50mm within a flexible or rigid wall, minimum thickness 100mm. Maximum aperture 730mm wide x 1200mm high - PP pipes.			
Penetration Specification	Collar Reference	Penetration Formation	Classification
PP pipe 32mm ø 2.9mm wall thickness	32mm x 30mm x 4mm CIPC	Cluster Formation of pipes with 0mm separation  There must be a minimum of 50mm from the edge of the seal	E1120 U/C
PP pipe 50mm ø 2.9mm wall thickness	50mm x 30mm x 4mm CIPC		
PP pipe 55mm ø 2.9mm - 4.4mm wall thickness	55mm x 30mm x 6mm CIPC		
PP pipe 63mm ø 2.9mm - 4.4mm wall thickness	63mm x 30mm x 6mm CIPC		
PP pipe 75mm ø 2.8mm - 6.7mm wall thickness	75mm x 30mm x 8mm CIPC		
PP pipe 82mm ø 2.8mm - 6.7mm wall thickness	82mm x 30mm x 8mm CIPC		
PP pipe 90mm ø 2.7mm - 10.0mm wall thickness	90mm x 30mm x 10mm CIPC		
PP pipe 110mm ø 2.7mm - 10.0mm wall thickness	110mm x 30mm x 10mm CIPC		
PP pipe 125mm ø 3.1mm wall thickness	125mm x 40mm x 12mm CIPC		

Walls minimum thickness 100mm

PFC Corofil Coated Panel installed as a pattress installation to each face of a wall

PVC-u Pipes according to EN1452

PFC Corofil Intumescent Pipe Collars installed on each outer face of a pattress installation of PFC Corofil Coated Panel 50mm within a flexible or rigid wall, minimum thickness 100mm. Maximum aperture 730mm wide x 1200mm high - PVC-u pipes.			
Penetration Specification	Collar Reference	Penetration Formation	Classification
PVC pipe 32mm ø 1.8mm wall thickness	32mm x 30mm x 4mm CIPC	Cluster Formation of pipes with 0mm separation  There must be a minimum of 50mm from the edge of the seal	E1120 U/C
PVC pipe 40mm ø 1.8mm wall thickness	40mm x 30mm x 4mm CIPC		
PVC pipe 55mm ø 1.8mm - 2.3mm wall thickness	55mm x 30mm x 6mm CIPC		
PVC pipe 63mm ø 2.3mm - 3.0mm wall thickness	63mm x 30mm x 6mm CIPC		
PVC pipe 75mm ø 3.1mm - 4.8mm wall thickness	75mm x 30mm x 8mm CIPC		
PVC pipe 82mm ø 3.1mm - 4.8mm wall thickness	82mm x 30mm x 8mm CIPC		
PVC pipe 90mm ø 4.2mm - 7.4mm wall thickness	90mm x 30mm x 10mm CIPC		
PVC pipe 110mm ø 4.2mm - 7.4mm wall thickness	110mm x 30mm x 10mm CIPC		
PVC pipe 125mm ø 6.0mm wall thickness	125mm x 40mm x 12mm CIPC		
PVC pipe 160mm ø 6.2mm - 9.5mm wall thickness	160mm x 40mm x 18mm CIPC		

Performance Data



Walls minimum thickness 100mm

PFC Corofil Coated Panel installed as a pattress installation to each face of a wall

PE Pipes according to EN ISO 15494

PFC Corofil Intumescent Pipe Collars installed on each outer face of a pattress installation of PFC Corofil Coated Panel 50mm within a flexible or rigid wall, minimum thickness 100mm. Maximum aperture 730mm wide x 1200mm high - PE pipes.			
Penetration Specification	Collar Reference	Penetration Formation	Classification
PE pipe 32mm ø 2.9mm wall thickness	32mm x 30mm x 4mm CIPC	Cluster Formation of pipes with 0mm separation  There must be a minimum of 50mm from the edge of the seal	EI120 U/C
PE pipe 40mm ø 2.9mm wall thickness	40mm x 30mm x 4mm CIPC		
PE pipe 55mm ø 2.9mm - 4.4mm wall thickness	55mm x 30mm x 6mm CIPC		
PE pipe 63mm ø 2.9mm - 4.4mm wall thickness	63mm x 30mm x 6mm CIPC		
PE pipe 75mm ø 2.8mm - 6.7mm wall thickness	75mm x 30mm x 8mm CIPC		
PE pipe 82mm ø 2.8mm - 6.7mm wall thickness	82mm x 30mm x 8mm CIPC		
PE pipe 90mm ø 2.7mm - 10.0mm wall thickness	90mm x 30mm x 10mm CIPC		
PE pipe 110mm ø 2.7mm - 10.0mm wall thickness	110mm x 30mm x 10mm CIPC		
PE pipe 125mm ø 3.1mm wall thickness	125mm x 40mm x 12mm CIPC		
PE pipe 160mm ø 4.9mm - 9.5mm wall thickness	160mm x 40mm x 18mm CIPC		

PP Pipes according to EN1451

PFC Corofil Intumescent Pipe Collars installed on each outer face of a pattress installation of PFC Corofil Coated Panel 50mm within a flexible or rigid wall, minimum thickness 100mm. Maximum aperture 730mm wide x 1200mm high - PP pipes.			
Penetration Specification	Collar Reference	Penetration Formation	Classification
PP pipe 32mm ø 2.9mm wall thickness	32mm x 30mm x 4mm CIPC	Cluster Formation of pipes with 0mm separation  There must be a minimum of 50mm from the edge of the seal	EI120 U/C
PP pipe 40mm ø 2.9mm wall thickness	40mm x 30mm x 4mm CIPC		
PP pipe 55mm ø 2.9mm - 4.4mm wall thickness	55mm x 30mm x 6mm CIPC		
PP pipe 63mm ø 2.9mm - 4.4mm wall thickness	63mm x 30mm x 6mm CIPC		
PP pipe 75mm ø 2.8mm - 6.7mm wall thickness	75mm x 30mm x 8mm CIPC		
PP pipe 82mm ø 2.8mm - 6.7mm wall thickness	82mm x 30mm x 8mm CIPC		
PP pipe 90mm ø 2.7mm - 10.0mm wall thickness	90mm x 30mm x 10mm CIPC		
PP pipe 110mm ø 2.7mm - 10.0mm wall thickness	110mm x 30mm x 10mm CIPC		
PP pipe 125mm ø 3.1mm wall thickness	125mm x 40mm x 12mm CIPC		
PP pipe 160mm ø 4.0mm - 14.6mm wall thickness	160mm x 40mm x 18mm CIPC		

Performance Data



Floor minimum thickness 150mm  
 Rigid Floor  
 PVC-u Pipes according to EN1452

PFC Corofil Intumescent Pipe Collars installed on the underside of a rigid floor, minimum thickness 150mm - PVC-u pipes.			
Penetration Specification	Collar Reference	Annulus Space	Classification
PVC pipe 32mm ø 1.8mm wall thickness	32mm x 30mm x 4mm CIPC	10mm	EI240 U/C
PVC pipe 40mm ø 1.8mm wall thickness	40mm x 30mm x 4mm CIPC		
PVC pipe 55mm ø 2.3mm - 3.0mm wall thickness	55mm x 30mm x 6mm CIPC		
PVC pipe 63mm ø 2.3mm - 3.0mm wall thickness	63mm x 30mm x 6mm CIPC		
PVC pipe 75mm ø 3.1mm - 4.8mm wall thickness	75mm x 30mm x 8mm CIPC		
PVC pipe 82mm ø 3.1mm - 4.8mm wall thickness	82mm x 30mm x 8mm CIPC		
PVC pipe 90mm ø 4.2mm - 7.4mm wall thickness	90mm x 30mm x 10mm CIPC		
PVC pipe 110mm ø 4.2mm - 7.4mm wall thickness	110mm x 30mm x 10mm CIPC		
PVC pipe 125mm ø 6.0mm wall thickness	125mm x 40mm x 12mm CIPC		
PVC pipe 160mm ø 6.2mm - 9.5mm wall thickness	160mm x 40mm x 18mm CIPC		

PE Pipes according to EN ISO 15494

PFC Corofil Intumescent Pipe Collars installed on the underside of a rigid floor, minimum thickness 150mm - PE pipes.			
Penetration Specification	Collar Reference	Annulus Space	Classification
PE pipe 32mm ø 2.9mm wall thickness	32mm x 30mm x 4mm CIPC	10mm	EI240 U/C
PE pipe 40mm ø 2.9mm wall thickness	40mm x 30mm x 4mm CIPC		
PE pipe 55mm ø 2.9mm - 4.4mm wall thickness	55mm x 30mm x 6mm CIPC		
PE pipe 63mm ø 2.9mm - 4.4mm wall thickness	63mm x 30mm x 6mm CIPC		
PE pipe 75mm ø 2.8mm - 6.7mm wall thickness	75mm x 30mm x 8mm CIPC		
PE pipe 82mm ø 2.8mm - 6.7mm wall thickness	82mm x 30mm x 8mm CIPC		
PE pipe 90mm ø 2.7mm - 10.0mm wall thickness	90mm x 30mm x 10mm CIPC		
PE pipe 110mm ø 2.7mm - 10.0mm wall thickness	110mm x 30mm x 10mm CIPC		
PE pipe 125mm ø 3.1mm wall thickness	125mm x 40mm x 12mm CIPC		
PE pipe 160mm ø 4.9mm - 9.5mm wall thickness	160mm x 40mm x 18mm CIPC		

**Performance Data**



Floor minimum thickness 150mm  
 Rigid Floor  
 PP Pipes according to EN1451

PFC Corofil Intumescent Pipe Collars installed on the underside of a rigid floor, minimum thickness 150mm - PP pipes.			
Penetration Specification	Collar Reference	Annulus Space	Classification
PP pipe 32mm ø 2.9mm wall thickness	32mm x 30mm x 4mm CIPC	10mm	EI240 U/C
PP pipe 40mm ø 2.9mm wall thickness	40mm x 30mm x 4mm CIPC		
PP pipe 55mm ø 2.9mm - 4.4mm wall thickness	55mm x 30mm x 6mm CIPC		
PP pipe 63mm ø 2.9mm - 4.4mm wall thickness	63mm x 30mm x 6mm CIPC		
PP pipe 75mm ø 2.8mm - 6.7mm wall thickness	75mm x 30mm x 8mm CIPC		
PP pipe 82mm ø 2.8mm - 6.7mm wall thickness	82mm x 30mm x 8mm CIPC		
PP pipe 90mm ø 2.7mm - 10.0mm wall thickness	90mm x 30mm x 10mm CIPC		
PP pipe 110mm ø 2.7mm - 10.0mm wall thickness	110mm x 30mm x 10mm CIPC		
PP pipe 125mm ø 3.1mm wall thickness	125mm x 40mm x 12mm CIPC		
PP pipe 160mm ø 4.0mm - 14.6mm wall thickness	160mm x 40mm x 18mm CIPC		

PP Pipes according to EN1451

PFC Corofil Intumescent Pipe Collars installed on both sides of a rigid floor, minimum thickness 150mm - PP pipes.			
Penetration Specification	Collar Reference	Annulus Space	Classification
PP pipe 110mm ø 2.7mm wall thickness	110mm x 30mm x 10mm CIPC	10mm	EI120 U/U
PP pipe 160mm ø 4.0mm wall thickness	160mm x 40mm x 18mm CIPC		EI120 C/U



Doc Reference		TDSCIPC	
Revision 1.1			
PB: SE	CB: CI	AB: UL	
This Copy		Review Date	
23/11/2023		03/08/2025	



King Georges Trading Estate | Davis Road | Chessington | KT9 1TT  
T. +44 (0) 208 391 0533  
E. [sales@pfc-corofil.com](mailto:sales@pfc-corofil.com) | [tech@pfc-corofil.com](mailto:tech@pfc-corofil.com) | W. [pfc-corofil.com](http://pfc-corofil.com)

This data sheet shows the only applications the product has been tested in. Please ensure the product has been tested in and is suitable for your application (see PFC Corofil terms and conditions 13.1.1). Downloaded and printed data sheets are uncontrolled. For latest copy please check [www.pfc-corofil.com](http://www.pfc-corofil.com)