





PENETRATION & LINEAR GAP SEALS SCHEME

Certificate number: IFCC 1584

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd part of the Kiwa UK Group

This is to certify that

Pre-Formed Components Ltd trading as:

PFC COROFIL

Units 3 & 4 King George Trading Estate Davis Road Surrey **KT9 1TT**

Telephone: +44 (0) 208 391 0533 www.pfc-corofil.com

Which manufacture the following systems:

PFC Corofil COSB 25 Open State Cavity Barriers

have satisfied the requirements of the Penetration and Linear Gap Seals scheme SDP 14 v1.6. This includes the testing of products to BS EN 1363-1:2012 in conjunction with ASFP TGD19 the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and reports are detailed on pages 2 and 3 of this certificate.

> Initial Certification: 4 August 2020 Re-issued: 03 September 2025 Valid to: 20 November 2030 Issue status: 6

> > **David Mowatt**

Head of IFC Certification / KIWA Group Limited

This certificate consists of 4 pages. Publication of this certificate is permitted.

IFC Certification Ltd

Ground Floor, Suite A, Building 2 Bear Brook Office Park

Walton Street

Aylesbury

Buckinghamshire

HP21 7GQ

United Kinadom

T +44 (0)1844 276920

www.ifccertification.com













The production of penetration & linear gap seals are manufactured in accordance with the following Field of Application Reports: PAR/23650/02, PAR/23650/03.

PAR/23650/02 - COSB 25 (1024) Scope of approval:

Maximum Air Gap (mm)	Void Width (mm) Including Air-Gap Note 4 and 5	Integrity (minutes)	Insulation (minutes)	Construction of Inner Wall Note 3	Fixings or L-Bracket Requirement
25	40	40 180 180 60 120 120		12.5mm thick Weather Defence board on steel frame systems, or concrete (refer to section 4.3 for further details)	Direct screw fix; See
	60			12.5mm thick Weather Defence board on steel frame systems, or concrete (refer to section 4.3 for further details)	Section 4.2
	300	120	120	12.5mm thick Weather Defence board on steel frame system or concrete (refer to section 4.3 for further details)	L-brackets; See Section
	450	90	90	12.5mm thick Weather Defence board on steel frame system or concrete (refer to section 4.3 for further details)	4.2

PAR/23650/02 - COSB 25 (1024) Summary of test evidence:

Test Number/ Specimen Reference	Cavity Width (mm)	Air Gap (mm)	Inner Wall Surface/ Construction Note 6	Insulation on Inner Wall	Fixed with Screws/ Brackets	Integrity Cotton Pad/ Sustained Flaming (minutes)	Insulation Surface/ Suspended (minutes)
WF433220 Specimen C	40	25	Concrete	None	Screws	190 ^{Note 7}	190 ^{Note 7}
WF436593 Specimen A	60	25	12.5mm thick Weather Defence board on steel frame system	25mm thick phenolic	Screws	120	120
WF416466 Specimen D	300	25	12.5mm thick Weather Defence Board on steel frame system	100mm thick PIR	3no ^{Note 8} MP Brackets	120	120
WF403555 Specimen C	450	25	Concrete	100mm thick PIR	3no ^{Note 8} MP Brackets	90	90

IFC Certification Ltd

Ground Floor, Suite A, Building 2

Bear Brook Office Park

Walton Street

Aylesbury

Buckinghamshire

HP21 7GQ

United Kingdom

T +44 (0)1844 276920 www.ifccertification.com Certification



Page 2 of 4







The production of penetration & linear gap seals are manufactured in accordance with the following Field of Application Reports: PAR/23650/02, PAR/23650/03.

PAR/23650/03 - COSB 25 (1074) Scope of approval:

Maximum Air Gap (mm)	Void Width (mm) Including Air-Gap Note 4 and 5	Integrity (minutes)	Insulation (minutes)	Construction of Inner Wall	Fixings or L-Bracket Requirement	
25	40	180 180		Concrete	Direct screw	
	60	120	120	12.5mm thick Weather Defence board on steel frame system	fix; See Section 4.2	
	300	120	120	Concrete Note 9		
	300	60	60	Concrete	L-brackets; See Section 4.2	
	450	60	60	10mm thick cement particleboard on steel frame system	7.2	

PAR/23650/03 - COSB 25 (1074) Summary of test evidence:

Test Number/ Specimen Reference	Cavity Width (mm)	Air Gap (mm)	Inner Wall Surface/ Construction Note 6	Insulation on Inner Wall	Fixed with Screws/ Brackets	Integrity Cotton Pad/ Sustained Flaming (minutes)	Insulation Surface/ Suspended (minutes)
WF433220 Specimen A	60	25	Concrete	None	Screws	190 ^{Note 7}	190 ^{Note 7}
WF436593A Specimen D	60	25	12.5mm thick Weather Defence board on steel frame system	25mm thick phenolic	Screws	120	120
WF436588A Specimen D	300	25	Concrete ^{Note 9}	100mm thick PIR	3no ^{Note 8} MP Brackets	120	120
WF394958 Specimen C	300	25	Concrete	100mm thick PIR	3no ^{Note 8} MP Brackets	60	60
WF430196 Specimen C	450	25	10m thick Cement Particle board on steel frame system	100mm thick PIR	3no ^{Note 8} HP Brackets	60	60

IFC Certification Ltd
Ground Floor, Suite A, Building 2
Bear Brook Office Park
Walton Street
Aylesbury
Buckinghamshire

United Kingdom **T** +44 (0)1844 276920

HP21 7GQ

www.ifccertification.com





Page 3 of 4







The production of penetration & linear gap seals are manufactured in accordance with the following Field of Application Reports: PAR/23650/02, PAR/23650/03.

Signed on behalf of Kiwa UK

David Mowatt Head of IFC Certification /

KIWA Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.

IFC Certification Ltd

Ground Floor, Suite A, Building 2 Bear Brook Office Park Walton Street Aylesbury Buckinghamshire HP21 7GQ United Kingdom

T +44 (0)1844 276920 www.ifccertification.com FC Certification



Page 4 of 4