



PENETRATION & LINEAR GAP SEALS SCHEME

Certificate number: IFCC 1669

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd part of the Kiwa UK Group

This is to certify that

Pre-Formed Components Ltd, trading as:

PFC COROFIL

Units 3 & 4

King George Trading Estate

Davis Road

Surrey

KT9 1TT

Telephone: +44 (0) 208 391 0533

www.pfc-corofil.com

Which manufacture the following systems:

CFSC PFC Corofil Fire Stop Compound

at manufacturing site: A-UA, have satisfied the requirements of the Penetrations and Linear Gap Seals scheme SDP-13 v1.6. This includes the testing of products to **BS EN 1366-3: 2009** and **BS EN 1363-1: 1999**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specifications to achieve **up to 240 minutes Fire Resistance (Integrity)** are given on page 2 of this certificate:

Initial Certification: 5th October 2021

Revised: 03 September 2025

Valid to: 4th October 2026

Issue status: 2

David Mowatt
Head of IFC Certification /
KIWA Group Limited

*This certificate consists of 2 pages.
Publication of this certificate is permitted.*





The production of penetration & linear gap seals are manufactured in accordance with the test reports referenced within the following table:

Product Description	Fire Rating	Test Report
Fire Stop Compound (CFSC)	E240	BMT/FEI/F14015

Signed on behalf of Kiwa UK

David Mowatt
Head of IFC Certification /
KIWA Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.

CERTIFICATE